

Three Main Questions:

- What does the Fire Code say about access requirements?
- When is parking allowed?
- Who has authority to enforce?




**Section 503.2.1 of
the California Fire
Code States:**

*“Fire apparatus
access roads shall
have an unobstructed
width of not less than
20 feet...and an
unobstructed vertical
clearance of 13 feet
6 inches.”*

When is Parking Allowed?


Parking is allowed on both sides of a roadway when:



The Road is a Minimum of 36 Feet Wide


When is Parking Allowed?

Parking is allowed on one side of a roadway when:



The Road is a Minimum of 28 Feet Wide

NO PARKING



**No parking signs
along roadways must
be properly posted in
order to be
enforceable!**

**Signs must be posted
every 150 feet.**

Authority to Enforce When “No Parking” Areas are Properly Posted



Public Roads =
Local Law
Enforcement

Authority to Enforce When “No Parking” Areas are Properly Posted



**Private Roads =
Citizens must
enter into an
agreement with
local law
enforcement.**



The Fire Department knows of no private roads located in Mission Canyon that are wide enough to allow parking.

**The Fire
Department
supports a “No
Parking” policy
on all roads in
Mission
Canyon that do
not meet Fire
Code
requirements.**

